

HAZARD ASSESSMENT

Member Name:

Montcalm Area ISD

Building(s) Inspected:

Central Montcalm HS & MS

Date:

05/30/2014

Loss Control Personnel:

skribs@setseg.org

Loss Control Recommendations

The following recommendations are offered to support improvements to your current safety program and help reduce your potential losses. If you need additional assistance, please e-mail me at skribs@setseg.org

Category:

Classroom

Title:

Artwork on walls

Recommendation:

Remove excess artwork and teaching materials that are attached to the classroom walls and ceilings per NFPA standards. Materials such as paper or cardboard are combustible and could contribute to rapid fire spread, as well as increase property losses and obstruct emergency egresses, no more than 20% of a wall can be covered with paper.

**Category:**

District Wide

Title:

Miscellaneous Items in the Classroom

Recommendation:

Restrict all miscellaneous items such as: microwaves, refrigerators, portable heater units, portable lamps, furniture, etc. from classrooms which can expose the district to a fire, burns, slips and falls or various injuries. These types of items could increase liability to employees, students and the general public. In addition, some of these items can increase electrical energy usage in your buildings.